

BID ADDENDUM

**FAILURE TO RETURN THIS BID ADDENDUM IN ACCORDANCE WITH INSTRUCTION MAY
SUBJECT YOUR BID TO REJECTION**

RFP NO: 2022-261

DESCRIPTION: Centerville Tower Shelter

RFP DUE DATE: September 15, 2021

RFP DUE TIME: 3:00 PM

ADDENDUM # 1: Page 8, Section 1.4 A. Revision as follows:

**The shelter shall be equipped with two 1.5 ton commercial-grade HVAC systems
(changed from .75 ton)**

INSTRUCTIONS

1. Return one properly executed copy of this Addendum with bid response or prior to Bid Opening Date/Time listed above.

2. Check **ONE** of the following options:

- Bid has **not** been mailed. **Any changes** resulting from this Addendum #: 1 are included in our bid.
- Bid has already been mailed. No changed resulted from this Addendum #: 1.
- Bid has already been mailed. Changed resulting from this Addendum #: 1 are as follows.

Execute Addendum:

Bidder: _____

Authorized Signature: _____

Name & Title (Print/Typed): _____

Date: _____