

Fire Suppression:

If a subdivision is not served by fire hydrants, the developer is required to provide fire fighting water sources consisting of a limited fire suppression system meeting the following requirements :

- (1) for a subdivision of fewer than 50 tracts, 2,500 gallons of storage; or
- (2) for a subdivision of 50 or more tracts, 5,000 gallons of storage

The fire fighting water sources and access road shall be indicated on the final plat.

All water tanks must be maintained in proper working condition and shall not be removed unless it is replaced with an equivalent water source that must be approved by the Navarro County Commissioners Court.