

ADDENDUM #1

for

Request for Proposals (RFP) for Radio Infrastructure Equipment and Installation

in Lamar County TX

Addendum dated 3/8/24

1. Page 3 – revised RFP Events Timetable as follows:

| <u>ACTION</u> | <u>DATE</u> |
|--|----------------------|
| Public media notification of RFP | March 3, 2024 |
| RFP packets made available for distribution | March 3, 2024 |
| Original Proposal deadline: | March 20, 2024 |
| Extended Proposal Deadline: Proposals must be received & date-stamped by <u>2:00pm</u> via Mail or drop off at the Auditor’s Office | April 3, 2024 |
| Proposal review and evaluation process begins | April 15, 2024 |
| Selection and negotiation with winning proposer, subject to Board approval | April 22, 2024 |
| Final Selection, Agreement/Contract | April 25, 2024 |

2. page 4 – D. Deadline for Submission: date revised to Wednesday, April 3, 2024.

3. page 12 - submission date revised to Wednesday, April 3, 2024

Required Elements in Response Format (page 14) #2 is revised as follows:

Tower Specifications:

Tower should accommodate any future loading beyond the specified (8) antennas and lighting kit, including microwave dishes, wave guides, and control station antennas.

Additional Site Requirements:

Provide and install one 25 feet in length x 8 feet in width ice bridge

Provide and install 12'x8 Steel Reinforced empty building with prefab conduit into the building for later electric and HVAC installation. No HVAC installation required

Provide and install a backup 22kw propane generator with an automatic transfer switch. The propane tank is not required to be installed by the vendor.

Provide compound finish (fence, rock) for surrounding the tower and shelter

Provide all lighting and electrical to the tower, building, and breaker box with a 200 amp electrical service.

NOTICE TO BIDDERS:

This addendum will be considered a part of the Contract Documents for the above referenced project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of scope of work differ from those in the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that such Bidder's Proposal is submitted with full knowledge of all modifications and supplementary data specified herein. Each bidder is required to acknowledge receipt of this addendum on the Bid Proposal form to be submitted with Bid Proposal. Please contact auditor@co.lamar.tx.us or dpurifoy@atcog.org with any questions.